

Moore 372 Indicator Station Model Selection

Model No. 3 7 2				
Power Requirement				
120 Vac (+10%, -15%) 47 to 63 Hz (see note 1)	A			
24 Vac (+10%, -15%) 47 to 63 Hz	B			
24 Vdc (+20%, -15%)	C			
220/240 Vac (+10%, -15%) 47 to 63 Hz (see note 1)	E			
*Note 1: On newer models the "E" is no longer available. It is merged with "A"; 120/240 VAC (85 to 264 VAC) 47 to 63 Hz. Please specify your power input requirement.				
Mounting Case				
Screw Terminals, 20		1		
Screw Terminals, 40		2		
Not Required		N		
Display Type				
Dual Bargraph, 64 segments			1	
Reserved for Factory Use				N
Electrical Approval				
Not Required				N
Non-Incendive (Div. 2) - FM Approved				F
Non-Incendive (Div. 2) - CSA Approved				C
Model No. 3 7 2				
Example: 3 7 2	A	2	1	N F

Please let us know the exact model you require. We can often customize units for your specific needs.



Classic Automation LLC
 795 Monroe Avenue
 Rochester, NY 14607
 USA

www.classicautomation.com

+1 (585) 241-6010

customerservice@classicautomation.com