

Moore 383 Multi-Point Display Station Model Selection

	Model No. 3 8 3						
Type							
Basic		B					
With Voltage Expander Board		V					
With Thermocouple Expander Board		T					
With RTD Expander Board		R					
Power Requirement							
120 Vac (+10%, -15%) 47 to 63 Hz (see note 1)			A				
24 Vac (+10%, -15%) 47 to 63 Hz			B				
24 Vdc (+20%, -15%)			C				
220/240 Vac (+10%, -15%) 47 to 63 Hz (see note 1)			E				
*Note 1: On newer models the "E" is no longer available. It is merged with "A"; 120/240 VAC (85 to 264 VAC) 47 to 63 Hz. Please specify your power input requirement.							
Mounting Case							
Screw Terminals, 20				1			
Screw Terminals, 40 (Required with types V, T, or R)				2			
Not Required				N			
Operators Panel							
Digital Display					1		
Not Required (Blank Panel)					N		
Reserved for Factory Use						N	
Data Communications Option							
Local Instrument Link (RS422, Half-Duplex)							1
Not Required							N
Electrical Classification							
Not Required							N
CSA							C
FM							F
	Model No. 3 8 3						
	Example: 3 8 3	B	A	1	1	N	1 F

Please let us know the exact model you require. We can often customize units for your specific needs.



Classic Automation LLC
 795 Monroe Avenue
 Rochester, NY 14607
 USA

www.classicautomation.com

+1 (585) 241-6010

customerservice@classicautomation.com